

Fifty mFRR EAM Recurring Meeting – Statnett, Svenska Kraftnät and Fifty, technical view

12.10.2021

Visit nordicbalancingmodel.net



2

Clarifications on bid submission

- A strict validation against the Gate closure time (GCT) is implemented
 - a bid message will be rejected if it contains at least one bid which has passed its GCT.
- Messages containing at least one faulty bid will be rejected as a whole
- In bid updates before GCT, only the updates should be sent in and not the entire bid series



ENERGINET FINGRID Statnett



News on BSP Test

Test environment will open in November



ENERGINET FINGRID Statnett